

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		1. CONTRACT ID CODE		PAGE 1 OF 2
2. AMENDMENT/MODIFICATION NO. Am-0004	3. EFFECTIVE DATE 02/12/04	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)	
6. ISSUED BY CODE U.S. Army Engineer District, Honolulu Corps of Engineers, Bldg. 230 ATTN: CEPOH-CT-C (Jennifer Ko) Fort Shafter, Hawaii 96858-5440		7. ADMINISTERED BY (If other than Item 6) CODE		

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)		(X)	9A. AMENDMENT OF SOLICITATION NO. W9128A-04-B-0001
		X	9B. DATED (SEE ITEM 11) 12/24/03
			10A. MODIFICATION OF CONTRACT/ORDER NO.
			10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE		

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ☐ is extended, ☒ is not extended.

Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. Accounting and Appropriation Data (If required)

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

(X)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc). SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

Invitation for Bids No. W9128A-04-B-0001, FY03 DAR Replacement Buildings, Pohakuloa Training Area, Island of Hawaii, Hawaii

(Continued on Page 2)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF SIGNER (Type or print)	
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY (Signature of Contracting Officer)	16C. DATE SIGNED

1. **CHANGES TO SPECIFICATIONS.** Attached hereto are new pages to the solicitation. The revision mark (Am-0004) is shown on each new page.

a. DELETED SECTIONS/PAGES/PARAGRAPHS. The following items are deleted from the solicitation.

Section 01010, Attachment 2 (1 page)

b. NEW SECTIONS/PAGES/PARAGRAPHS. The following are new pages to the solicitation.

Section 00900, Miscellaneous Attachment - Contractor Questions and Responses (1 page)
Section 01010, Attachment 2 (1 page)

2. The bid opening date of February 20, 2004, 2:00 P.M., Hawaiian Standard Time, remains unchanged.

SECTION 00900
MISCELLANEOUS ATTACHMENT
(Contractor Questions and Responses)

Q1. (This is clarification to the response issued in Am-0003, dated 1/30/04 for Q7(f)):
Q7(f). Par. S-36.21 indicates that water and electricity are to be provided by the government at no cost to the contractor. Please confirm that sufficient quantities of water are available for construction and that it can be obtained without unreasonable delay to the performance of work. Please also specify whether electrical service and water must be metered and accounted for.

RESPONSE: The Government WILL NOT provide any water and electricity free of charge, See Section 00800, paragraph S-36.21, "Availability and Use of Utility Services". Contractor is required to provide their own water supply, will not be able to tap into existing water source at the project site.


Q2. Amendment No. 3 Section 00800 Page 13 of 16 Paragraph S-36.21
Availability and Use of Utility Services.

Amendment No. 3 Section 00900 Page 8 of 10 Question Q7(f) and Response.
Paragraph S-36-21 clarifies that there will be no utilities available free of charge from the government. Q7(f) inquired whether or not sufficient quantities of water for construction can be obtained, and the second sentence of the response was incomplete. Please confirm that the contractor will be permitted to tap into existing water sources on site and specify the quantity of water available for dust control and general construction use.

RESPONSE: See response to Q1 above. Contractor is not permitted to tap into existing water sources at the project site. Contractors must provide their own water supply for use at the project site.

Q3. At the recreation center building, division 4, subsection C, the lava rock cultured stone by Stucco Stone Products is no longer being manufactured. I called Ameron HC&D and they said that they have a comparable product from the Philippines. Is this product acceptable?

RESPONSE: On Sheet A-8 of the work plans for the Recreation Center, under Division 04- MASONRY (SEE STRUCTURAL), item (C) is amended to read as follows: Lava Rock - Veneer shall be local stock or cultured stone. Submit sample panel, minimum 3' x 3', for government approval.



SECTION 01010
Am. 0004

ATTACHMENT 2